

Schena, Cristeen

From: Gardner, Crystal I NAE <Crystal.I.Gardner@usace.army.mil>
Sent: Wednesday, August 13, 2014 11:58 AM
To: Mcinerny, Joseph P NAE
Subject: FW: Proposed US Army Reserve Military Construction Project, 103 and 135 East Washington St, North Attleborough, MA wetland inquiry (UNCLASSIFIED)

Classification: UNCLASSIFIED

Caveats: NONE

-----Original Message-----

From: Redlinger, Joseph M NAE
Sent: Tuesday, June 14, 2011 1:03 PM
To: Gardner, Crystal I NAE
Subject: RE: Proposed US Army Reserve Military Construction Project, 103 and 135 East Washington St, North Attleborough, MA wetland inquiry (UNCLASSIFIED)

Classification: UNCLASSIFIED

Caveats: NONE

Crystal,
You need to check with OC to see if it can be released.

JoeR

-----Original Message-----

From: Gardner, Crystal I NAE
Sent: Wednesday, June 08, 2011 10:21 AM
To: Redlinger, Joseph M NAE
Subject: FW: Proposed US Army Reserve Military Construction Project, 103 and 135 East Washington St, North Attleborough, MA wetland inquiry (UNCLASSIFIED)

Classification: UNCLASSIFIED

Caveats: NONE

Joe:

Find attached a letter written to EPA from Jeffrey Hrzic, Chief Environmental Review, Fort Dix, NJ. EPA has requested some information from our files regarding our current violation of the site. Karen wanted me to check with to see if you are ok with its release. I was told you were on TDY until Monday and I will be on leave starting this afternoon till Monday. So I will get with you on Monday so that we can make a determination on their request.

Crystal

-----Original Message-----

From: reiner.ed@epamail.epa.gov [mailto:reiner.ed@epamail.epa.gov]
Sent: Wednesday, June 08, 2011 9:41 AM
To: Gardner, Crystal I NAE

Subject: Fw: Proposed US Army Reserve Military Construction Project, 103 and 135 East Washington St, North Attleborough, MA wetland inquiry

Edward Reiner
Senior Wetland Scientist
USEPA
5 Post Office Square.
Suite 100 (OEP05-2)
Boston, MA 02109-3912

Ph. (617) 918-1692
Fx. (617) 918-0692
e. Reiner.Ed@epa.gov

----- Forwarded by Ed Reiner/R1/USEPA/US on 06/08/2011 09:40 AM -----

From: Ed Reiner/R1/USEPA/US

To: Elizabeth.Kouloheras@state.ma.us, MJames.Sheehan@nae02.usace.army.mil,
Karen.K.adams@nae02.usace.army.mil, Davidj Gray/R1/USEPA/US, Thelma Murphy/R1/USEPA/US@EPA

Date: 06/07/2011 08:26 AM

Subject: Proposed US Army Reserve Military Construction Project, 103 and 135 East Washington St, North Attleborough, MA wetland inquiry

EPA received a letter from the Department of the Army, Headquarters, 99th Regional Support Command in Fort Dix, NJ, informing us of the preparation of an Environmental Assessment for the proposed construction and operation of an Army Reserve Center to be located in North Attleborough, MA. The letter is attached. The address of the parcel is listed as 103 and 135 East Washington Street in North Attleborough which had a file number MA DEP 243-0722 dated 8/8/2008 by David Canata of North One Development Corp.

It appears from current birds eye photos of the site on Google Maps or Bing that soils have been imported to the site disturbing vegetation on the site.

Can you please inform me what you know of the activity on this site to date and if the soil importing activity is legal or not,

Was a SWPPC permit applied for at this location sometime around 8/8/2008.

(See attached file: US Army Reserve North Attleborough_5-13-11.pdf)

(See attached file: wetlands12k_external-dell10922112102.jpg)

243-072	8/8/200	DAVI	CANNAT	135 EAST	NORTH ONE	S	NORTH	This project is subject to the new Stormwater Regulations,
2	8	D	A	WASHINGTON	DEVELOPMEN	E	ATTLEBOROUGH	310 CMR 10.05(6)(b) and (k-q), effective January 2, 2008.
				N STREET	T CORP.		H	Please submit Stormwater Report
								http://mass.gov/dep/water/laws/swcheck.doc found in the new
								Stormwater Handbook 2008. Please submit Stormwater Report.
								Among the many changes from the Stormwater Policy, please
								note that Standard 3, recharge, and Standard 4, water
								quality, have substantial changes.

Edward Reiner
Senior Wetland Scientist
USEPA
5 Post Office Square.
Suite 100 (OEP05-2)
Boston, MA 02109-3912
Ph. (617) 918-1692
Fx. (617) 918-0692
e. Reiner.Ed@epa.gov

Classification: UNCLASSIFIED
Caveats: NONE

Classification: UNCLASSIFIED
Caveats: NONE

Classification: UNCLASSIFIED

Caveats: NONE